

SINTEF Product Certificate

No. 3161

Issued: 01.07.2015
Renewed: 24.06.2025
Valid until: 01.07.2030
Provided listed on
www.sintefcertification.no

SINTEF confirms that

Resideo Braukmann D06F-LFA and D06F-LFE pressure reducing valves

complies with the requirements in

- › EN 1567
- › NKB Product Rules no. 4
- › Elastomer Guideline (*) and DVGW W 270 (*)



Certificate holder

Pittway Sàrl
A3 - ZA La Pièce 6
1180 Rolle
Switzerland

Manufacturer

Ademco 1 GmbH
Hardhofweg 40
74821 Mosbach
Germany

Factory production control

The manufacturing of the product is subject to factory production control in accordance with the provisions in EN ISO/IEC 17065.

Product description

Resideo Braukmann D06F-LFA and D06F-LFE pressure reducing valves in DZR brass.

The following models are included:

- › D06F-1/2LFA and D06F-1/2LFE – DN15
- › D06F-3/4LFA and D06F-3/4LFE – DN20
- › D06F-1LFA and D06F-1LFE – DN25
- › D06F-1 1/4LFA and D06F-1 1/4LFE – DN32
- › D06F-1 1/2LFA and D06F-1 1/2LFE – DN40
- › D06F-2LFA and D06F-2LFE – DN50

Performance requirements in TEK

Working pressure

The product meets the performance requirements at normal working pressure.

The product has been tested for 16 bar water pressure.

Effect on drinking water

The product does not submit substances which reduce drinking water quality or cause danger to health.

The product has been tested for release of heavy metals to drinking water according to NKB Product Rules no. 4.

The product has been tested for releases to drinking water according to Elastomer Guideline

Other requirements

Marking

The product may be marked with the SINTEF certification mark as shown above. The mark may also be used on packaging and marketing materials concerning the certified product.

Dezincification resistance

The product has been tested for dezincification resistance according to EN ISO 6509.



Anne-Jorunn Enstad
Certification Manager

