

SINTEF Product Certificate

No. 4049

Issued: 28.01.2026

Revised: 03.06.2026

Valid until: 01.02.2031

Provided listed on

www.sintefcertification.no

SINTEF confirms that

Halcor TALOS copper tubes

complies with the requirements in

› **EN 1057:2006+A1:2010**



Certificate holder

Elvalhalcor S.A.
62nd km National Road Athens-Lamia
32011 Inofyta Viotia, Greece

Manufacturer

Elvalhalcor S.A. (Copper and alloys extrusion division)
62nd km National Road Athens-Lamia
32011 Inofyta Viotia, Greece

Factory production control

The manufacturing of the product is subject to factory production control in accordance with the provisions in EN ISO/IEC 17065.

Product description

Halcor TALOS copper tubes, type R250 (half hard copper tubes) and R290 (hard copper tubes).

The following dimensions are included for type R250:

12 x 1.0 mm, 15 x 1.0 mm, 18 x 1.0 mm, 22 x 1.0 mm, 28 x 1.0 mm, 35 x 1.5 mm, 42 x 1.5 mm, 54 x 1.5 mm

The following dimensions are included for type R290:

10 x 0.8 mm, 12 x 1.0 mm, 15 x 1.0 mm, 18 x 1.0 mm, 22 x 1.0 mm, 28 x 1.0 mm, 28 x 1.2 mm, 35 x 1.5 mm, 42 x 1.5 mm, 54 x 1.5 mm, 64 x 2.0 mm, 76.1 x 2.0 mm, 88.9 x 2.0 mm, 108 x 2.5 mm

Performance requirements in TEK

Working pressure

The product meets the performance requirements at normal working pressure.

The product has been tested for 16 bar water pressure.

Effect on drinking water

The product does not submit substances which reduce drinking water quality or cause danger to health.

Other requirements

Marking

The product may be marked with the SINTEF certification mark as shown above. The mark may also be used on packaging and marketing materials concerning the certified product.



Anne-Jorunn Enstad
Certification Manager

